



UNITED STATES PATENT AND TRADEMARK OFFICE

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office
Address: COMMISSIONER FOR PATENTS
P.O. Box 1450
Alexandria, Virginia 22313-1450
www.uspto.gov

APPLICATION NO.	FILING DATE	FIRST NAMED INVENTOR	ATTORNEY DOCKET NO.	CONFIRMATION NO.
10/719,163	11/21/2003	Randy J. Longsdorf	R11.12-0812	2356
27367 7590 06/09/2010 WESTMAN CHAMPLIN & KELLY, P.A. SUITE 1400 900 SECOND AVENUE SOUTH MINNEAPOLIS, MN 55402			EXAMINER NORTON, JENNIFER L	
			ART UNIT	PAPER NUMBER
			2121	
			MAIL DATE	DELIVERY MODE
			06/09/2010	PAPER

Please find below and/or attached an Office communication concerning this application or proceeding.

The time period for reply, if any, is set in the attached communication.

Office Action Summary

Application No.

10/719,163

Applicant(s)

LONGSDORF ET AL.

Examiner

JENNIFER L. NORTON

Art Unit

2121

-- The MAILING DATE of this communication appears on the cover sheet with the correspondence address --
Period for Reply

A SHORTENED STATUTORY PERIOD FOR REPLY IS SET TO EXPIRE 3 MONTH(S) OR THIRTY (30) DAYS, WHICHEVER IS LONGER, FROM THE MAILING DATE OF THIS COMMUNICATION.

- Extensions of time may be available under the provisions of 37 CFR 1.136(a). In no event, however, may a reply be timely filed after SIX (6) MONTHS from the mailing date of this communication.
- If NO period for reply is specified above, the maximum statutory period will apply and will expire SIX (6) MONTHS from the mailing date of this communication.
- Failure to reply within the set or extended period for reply will, by statute, cause the application to become ABANDONED (35 U.S.C. § 133). Any reply received by the Office later than three months after the mailing date of this communication, even if timely filed, may reduce any earned patent term adjustment. See 37 CFR 1.704(b).

Status

- 1) ☒ Responsive to communication(s) filed on 29 April 2010.
- 2a) ☐ This action is **FINAL**. 2b) ☒ This action is non-final.
- 3) ☐ Since this application is in condition for allowance except for formal matters, prosecution as to the merits is closed in accordance with the practice under *Ex parte Quayle*, 1935 C.D. 11, 453 O.G. 213.

Disposition of Claims

- 4) ☒ Claim(s) 1, 4-24, 26-29 and 32-34 is/are pending in the application.
- 4a) Of the above claim(s) _____ is/are withdrawn from consideration.
- 5) ☐ Claim(s) _____ is/are allowed.
- 6) ☒ Claim(s) 1, 4-24, 26-29 and 32-34 is/are rejected.
- 7) ☐ Claim(s) _____ is/are objected to.
- 8) ☐ Claim(s) _____ are subject to restriction and/or election requirement.

Application Papers

- 9) ☐ The specification is objected to by the Examiner.
- 10) ☒ The drawing(s) filed on 18 August 2008 is/are: a) ☒ accepted or b) ☐ objected to by the Examiner.
Applicant may not request that any objection to the drawing(s) be held in abeyance. See 37 CFR 1.85(a).
Replacement drawing sheet(s) including the correction is required if the drawing(s) is objected to. See 37 CFR 1.121(d).
- 11) ☐ The oath or declaration is objected to by the Examiner. Note the attached Office Action or form PTO-152.

Priority under 35 U.S.C. § 119

- 12) ☐ Acknowledgment is made of a claim for foreign priority under 35 U.S.C. § 119(a)-(d) or (f).
- a) ☐ All b) ☐ Some * c) ☐ None of:
- ☐ Certified copies of the priority documents have been received.
 - ☐ Certified copies of the priority documents have been received in Application No. _____.
 - ☐ Copies of the certified copies of the priority documents have been received in this National Stage application from the International Bureau (PCT Rule 17.2(a)).

* See the attached detailed Office action for a list of the certified copies not received.

Attachment(s)

- 1) ☒ Notice of References Cited (PTO-892)
- 2) ☐ Notice of Draftperson's Patent Drawing Review (PTO-948)
- 3) ☐ Information Disclosure Statement(s) (PTO/SB/08)
Paper No(s)/Mail Date _____
- 4) ☐ Interview Summary (PTO-413)
Paper No(s)/Mail Date _____
- 5) ☐ Notice of Informal Patent Application
- 6) ☐ Other: _____

DETAILED ACTION

1. The following is a **Non-Final Office Action** in response to the Request for Continued Examination filed on 29 April 2010. Claims 1 and 26-28 have been amended (per Claims filed on 31 March 2010). Claims 2, 3 and 38 were previously cancelled. Claims 25, 30, 31, 35-37 and 39-53 have been cancelled (per Claims filed on 31 March 2010). Claims 1, 4-24, 26-29 and 32-34 are pending in this application.

Response to Arguments

2. Applicant's arguments see Remarks pg. 7, filed 31 March 2010 with respect to the rejection of claims 1, 4-24, 26-29 and 32-34 under 35 U.S.C 103(a) have been fully considered but are moot in view of the new ground(s) of rejection.

3. Claims 1, 4-24, 26-29 and 32-34 stand rejected under 35 U.S.C. 103(a) as set forth below.

Claim Rejections - 35 USC § 103

4. The following is a quotation of 35 U.S.C. 103(a) which forms the basis for all obviousness rejections set forth in this Office action:

(a) A patent may not be obtained though the invention is not identically disclosed or described as set forth in section 102 of this title, if the differences between the subject matter sought to be patented and the prior art are such that the subject matter as a whole would have been obvious at the time the invention was made to a person having ordinary skill in the art to which said subject matter pertains. Patentability shall not be negated by the manner in which the invention was made.

5. **Claims 1, 4-7, 10-12, 15-24, 26-29 and 32-34** are rejected under 35 U.S.C. 103(a) as being unpatentable over U.S. Patent No. 6,017,143 (hereinafter **Eryurek**), in view of U.S. Patent No. 7,054,765 (hereinafter **Flaemig**) in further view of U.S. Patent No. 6,957,115 (herein after **Meyer-Grafe**).

(**Eryurek** as set forth below generally discloses the basic invention.)

Regarding independent claim 1, Eryurek teaches to,

- a transmitter for use in an industrial process, (col. 3, lines 9-12) comprising:
- a process variable sensor (Fig. 1, element 16) to sense a process variable (col. 3, lines 9-12);
- a databus for digital data communication between devices/components (col. 2, line 65-col. 3, line 33 and Fig. 1);
- the safety response circuitry (abstract, col. 1, lines 44-64 and Fig. 1) comprising:
 - a device interface to couple to the process device (abstract) and provide an output related to operation of a component of the process device (col. 1, lines 44-45; an input which receives a process signal);
 - the device interface comprises of communication between the component of the device and a microprocessor of the device (col. 4, lines 11-28);
 - a component monitor in the process device (monitors the process and performs computations, col. 3, lines 22-25; col. 8, line 30-col. 9, line 14), to monitor operation

of the component based upon the output from the device interface and responsively identify a safety event of the component (col. 8, line 30-col. 9, line 14; computing circuitry provides an event output ... in response to, col. 1, lines 53-57; provide an event output, col. 1, line 44-64; rules are selected to detect events, col. 1, lines 44-64); and provide a safety event output (col. 1, lines 31-36; typically, ... pressure is monitored and an alarm is sounded or a safety shutdown is initiated if the process variable exceeds predetermined limits) indicative of a failure of the component (col. 6, lines 21-42); and

- a safety response module in the process device to respond to the safety event of the component based upon the safety event output (col. 1, lines 31-36; typically, ... pressure is monitored and an alarm is sounded or a safety shutdown is initiated if the process variable exceeds predetermined limits) in accordance with a safety response (col. 6, lines 21-42; provide an event output and col. 1, line 44-64; rules are selected to detect events).
- Eryurek further teaches to detecting faulty device, identify device/component (Fig. 6).

Eryurek does not expressly teach to a component monitor in the process device to monitor data carried on the databus, and the device interface component monitor and safety response module are isolated from other components of the process device to provide redundancy.

Flaemig teaches to a component monitor (Fig. 1, element 12 of Fig. 1, element 1) to monitor operation of the device (col. 3, lines 21-26 and Fig. 1, element 4), and isolating components (Fig. 1, element 12) from other components of the process device to provide redundancy (col. 1, lines 59-65, col. 2, lines 35-37 and Fig. 1, element 1).

Flaemig does not expressly teach a component monitor in the process device to monitor data carried on the databus.

Meyer-Grafe teaches to a component monitor to monitor data carried on the databus (col. 2, lines 19-23 and col. 6, lines 47-54).

It would have been obvious to a person of ordinary skill in the art at the time of Applicant's invention to modify the teaching of **Eryurek** to include a component monitor to monitor operation of the device, and isolating components from other components of the process device to provide redundancy to increase the integrity of measurement by positively notifying false indications are caused by loss of a pressure transmission fluid, which could previously go undetected, as well as, providing error information for failure of external conversion electronics and software (Flaemig: col. 1, lines 66-67 and col. 2, lines 1-7); a component to monitor data carried on the databus to ensure the required safety criteria is fulfilled with a minimum amount of hardware redundancy in a safety-related automation bus system (Meyer-Grafe: col. 2, lines 4-7).

Furthermore, it would have been obvious to a person of ordinary skill in the art at time the invention was made to include a device which includes a device interface, component monitor and safety response module, and a databus of the process device which is used to transfer digital data between the component of the device and a microprocessor of the device since it has been held that forming in one piece an article which has formerly been formed in two pieces and put together involves only routine skill in the art. *Howard v. Detroit Stove Works*, 150 U.S. 164 (1893).

Regarding dependent claim 4,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the device interface comprises a sensor coupled to the process device (Fig. 1, element 16; sensor, col. 3, lines 9-12 and col. 4, lines 35-42).

Regarding dependent claim 5,

Eryurek teaches as set forth above to an apparatus wherein the process device couples to a process control loop and the sensor is to monitor current flow in the process control loop (col. 4, lines 38-42; diagnostic signal sensed by sensor and col. 2, lines 46-57; diagnostic signals include ... electrical voltage, current ...).

Regarding dependent claim 6,

Eryurek teaches as set forth above to an apparatus wherein the component monitor compares the sensed current with a current value (col. 4, lines 38-42; diagnostic signal sensed by sensor; col. 2, lines 46-57; diagnostic signals include ... electrical voltage, current ..., col. 8, lines 42-44; determines faulty).

Regarding dependent claim 7,

Eryurek teaches as set forth above to an apparatus wherein the safety response module controls the current in a process control loop based upon a safety failure (col. 4, lines 38-42; diagnostic signal sensed by sensor, col. 2, lines 46-57; diagnostic signals include ... electrical voltage, current ..., col. 8, lines 42-44; determines faulty and col. 6, lines 21-42; statistical parameter mean, current means).

Regarding dependent claim 10,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the device interface couples to a memory (col. 1, lines 44-46; input, memory).

Regarding dependent claim 11,

Eryurek teaches as set forth above to an apparatus wherein the component monitor is to detect errors in the data stored in the memory (col. 8, line 42–col. 9, line 10).

Regarding dependent claim 12,

Eryurek teaches as set forth above to an apparatus wherein the safety response module provides an alarm output (col. 1, lines 34-35; alarm is sounded).

Regarding dependent claim 15,

Eryurek teaches as set forth above to an apparatus wherein the safety response module attempts to compensate for the safety failure (col. 6, lines 21-42; defines the acceptable variations,).

Regarding dependent claim 16,

Eryurek teaches as set forth above to an apparatus wherein the safety response module corrects for errors in data in the device (col. 6, lines 56-59; adjusted by adjusting the sensitivity parameter).

Regarding dependent claim 17,

Eryurek teaches as set forth above to the apparatus of claim 16 wherein the safety response module interpolates between data points in order to correct a data error (col. 3, lines 15-33; adjusting value by changing the flow in pipe).

Regarding dependent claim 18,

Eryurek teaches as set forth above to the apparatus of claim 16 wherein the safety response module holds a previous data point (col. 5, lines 51-53).

Regarding dependent claim 19,

Eryurek teaches as set forth above to an apparatus wherein the sensor comprises a voltage sensor (col. 2, lines 42-64; electrical voltage ... or any parameter ... maybe detected).

Regarding dependent claim 20,

Eryurek teaches as set forth above to an apparatus wherein a current sensor (col. 2, lines 42-64; current ... or any parameter ... maybe detected).

Regarding dependent claim 22,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the component monitor comprises software implemented in a microprocessor of the device (col. 10, lines 2-5).

Regarding dependent claim 23,

Eryurek teaches as set forth above to an apparatus wherein the safety event comprises a possibility of a future component failure (col. 1, lines 34-36; exceed predefined limits).

Regarding dependent claim 24,

Eryurek teaches as set forth above to an apparatus wherein the safety event comprises a detection of a component failure (col. 9, lines 43-45; faulty device).

Regarding dependent claim 25,

Eryurek teaches as set forth above to a process variable transmitter including the apparatus of claim 1 (Fig. 1, element 12).

Regarding dependent claim 26,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the safety response module is implemented in a feature module which couples to a sensor module of the process device (col. 10, lines 2-5 and Fig. 2).

Regarding dependent claim 27,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the safety response module is implemented in a feature module which couples to a plurality of sensor modules (col. 10, lines 2-5, col. 8, lines 65-66 and Fig. 2).

Regarding dependent claims 21 and 28,

Eryurek teaches as set forth above to an apparatus wherein the component monitor is to monitor data carried on the databus (monitors the process and performs computations, col. 3, lines 22-25; col. 8, line 30-col. 9, line 14).

Regarding dependent claim 29,

Eryurek teaches as set forth above to the apparatus of claim 1 including a display and wherein the component monitors data sent to the display (col. 4, lines 44-58; a display).

Regarding dependent claim 32,

Eryurek teaches as set forth above the apparatus of claim 1 wherein the component monitor monitors a plurality of process devices (col. 3, lines 34-36 and Fig. 6, element 208).

Regarding dependent claim 33,

Eryurek teaches as set forth above to the apparatus of claim 1 wherein the component monitor and safety response module are implemented in software (col. 10, lines 2-5).

Regarding dependent claim 34,

Eryurek does not expressly teach an apparatus wherein the software is to upgrade an existing process device.

Flaemig teaches to the software (Fig. 1, element 6; i.e. software of the processor) is to upgrade an existing process device (col. 1, lines 59-65 and col. 2, lines 44-50; i.e. the processor's capability to generate signals associated with the add-on device).

It would have been obvious to a person of ordinary skill in the art at the time of Applicant's invention to modify the teaching of **Eryurek** to include the software is to upgrade an existing process device to increase the integrity of measurement by positively notifying false indications are caused by loss of a pressure transmission fluid, which could previously go undetected; as well as, providing error information for failure of external conversion electronics and software (Flaemig: col. 1, lines 66-67 and col. 2, lines 1-7).

6. **Claim 8 is rejected** under 35 U.S.C. 103(a) as being unpatentable over **Eryurek** in view of **Flaemig** in further view of **Meyer-Grafe** and U.S. Patent No. 6,647,301 (hereinafter **Sederlund**).

Regarding dependent claim 8,

Eryurek teaches to the device interface (abstract and col. 1, lines 44-45; an input which receives a process signal).

Eryurek does not expressly teach a watch dog circuit.

Neither **Flaemig** nor **Meyer-Grafe** expressly teach a watch dog circuit.

Sederlund teaches a watch dog circuit (col. 7, lines 19-20 and Fig. 35).

It would have been obvious to a person of ordinary skill in the art at the time of Applicant's invention to modify the teaching of **Eryurek** in view of **Flaemig** in further view of **Meyer-Grafe** to include a watch dog circuit for the purpose of providing a rule set (col. 12, lines 12-60).

7. **Claim 9 is rejected** under 35 U.S.C. 103(a) as being unpatentable over **Eryurek** in view of **Flaemig** in further view of **Meyer-Grafe** and U.S. Patent No. 6,476,522 (hereinafter **Hays**).

Regarding dependent claim 9,

Eryurek teaches to an apparatus with a device interface (abstract and col. 1, lines 44-45).

Eryurek does not expressly teach to sensing power drawn by circuitry of the process device.

Neither **Flaemig** nor **Meyer-Grafe** expressly teach sensing power drawn by circuitry of the process device.

Hays teaches sensing power drawn by circuitry of the process device (abstract and col. 1, lines 7-8; electronic components for controlling power drawn by a measurement device) for the purpose of controlling power drawn (col. 1, lines 7-8).

It would have been obvious to a person of ordinary skill in the art at the time of applicant's invention to modify the teaching of **Eryurek** in view of **Flaemig** in further view of **Meyer-Grafe** to include sensing power drawn by circuitry of the process device to advantageously maximize power available for any type of sensor in the measurement device, as well as, provide a measurement device that supports a longer length of the power link (col. 2, lines 38-48).

8. **Claims 13 and 14 are rejected** under 35 U.S.C. 103(a) as being unpatentable over **Eryurek** in view of **Flaemig**, and further in view of **Meyer-Grafe** and U.S. Patent No. 4,356,900 (hereinafter **Sommer**).

Regarding dependent claims 13 and 14,

Eryurek teaches to an apparatus with a device interface (abstract and col. 1, lines 44-45).

Eryurek does not expressly teach the safety response module disconnects the process device from a process control loop.

Neither **Flaemig** nor **Meyer-Grafe** expressly teach the safety response module disconnects the process device from a process control loop.

Sommer teaches the safety response module disconnects the process device from a process control loop (abstract; deactuate the clutch unit so as to disconnect the motor from the driving apparatus in response to abnormal operating conditions) for the purpose of safety (abstract).

It would have been obvious to a person of ordinary skill in the art at the time of applicant's invention to modify the teaching of **Eryurek** in view of **Flaemig** in further view of **Meyer-Grafe** to include the safety response module disconnects the process device from a process control loop to achieve a soft start which enables the conveyor belt to tension in a generally even manner whereby any backlash or rebounding is

minimized (col. 1, lines 35-39); as well as, provide an improved cam type control valve which is extremely resistant to operation degradation as a result of contaminants in the actuating fluid and which operates reliably to apply actuating fluid to the clutch unit in accordance with a predetermined profile so as to smoothly bring the driven apparatus up to full operating speed within a minimum amount of time and with a minimum amount of clutch slippage (col. 1, lines 62-67 and col. 2, lines 1-2).

Conclusion

The prior art made of record and not relied upon is considered pertinent to Applicant's disclosure.

The following references are cited to further show the state of the art with respect to diagnostic monitoring and control systems.

U.S. Patent No. 7,667,352 discloses a sensor unit with a safety system for use with a signal generator, where at least one evaluation unit is provided for evaluating a signal from a sensor and for producing a first trigger signal based on the signal.

Any inquiry concerning this communication or earlier communications from the examiner should be directed to JENNIFER L. NORTON whose telephone number is

(571)272-3694. The examiner can normally be reached on Monday-Friday between 9:00 a.m. - 5:30 p.m..

If attempts to reach the examiner by telephone are unsuccessful, the examiner's supervisor, Albert Decady can be reached on 571-272-3819. The fax phone number for the organization where this application or proceeding is assigned is 571-273-8300.

Information regarding the status of an application may be obtained from the Patent Application Information Retrieval (PAIR) system. Status information for published applications may be obtained from either Private PAIR or Public PAIR. Status information for unpublished applications is available through Private PAIR only. For more information about the PAIR system, see <http://pair-direct.uspto.gov>. Should you have questions on access to the Private PAIR system, contact the Electronic Business Center (EBC) at 866-217-9197 (toll-free). If you would like assistance from a USPTO Customer Service Representative or access to the automated information system, call 800-786-9199 (IN USA OR CANADA) or 571-272-1000.

/Albert DeCady/
Supervisory Patent Examiner
Art Unit 2121

/JLN/